

# Cambridge Fire Department Construction Site Checklist





# CONSTRUCTION SITE CHECKLIST

**CAMBRIDGE FIRE DEPARTMENT  
BUREAU OF FIRE PREVENTION**

491 Broadway

Cambridge, MA 02138

Phone (617) 349-4918

Fax (617) 349-4979

[www.cambridgema.gov/cfd](http://www.cambridgema.gov/cfd)

Fire Companies are to use this form when Inspecting Construction Sites within their Districts.

Fire Company (E) (L) (S) (R) \_\_\_\_\_ Date \_\_\_\_\_ Address \_\_\_\_\_

General Contractor Company Name \_\_\_\_\_

General Contractor Company Address \_\_\_\_\_

General Contractor Company Phone Number \_\_\_\_\_ Supervisor Name \_\_\_\_\_

Circle Appropriate Answer and Provide Explanation to Items Circled in Column 2

Column 1

Column 2

Column 3

Fire Department Access  
Explanation \_\_\_\_\_

Yes

No

Emergency Contact Information Posted  
Explanation \_\_\_\_\_

Yes

No

Standpipe (Required when Project Reaches 40 Feet in Height)  
Explanation \_\_\_\_\_

Yes

No

N/A (under 40 feet)

Fire Department Connection and Visible Signage  
Explanation \_\_\_\_\_

Yes

No

N/A

Portable Fire Extinguishers Accessible and In Working Order  
Explanation \_\_\_\_\_

Yes

No

N/A

Fire Protection System (Sprinklers) In Working Order Explanation _____	Yes	No	N/A
Fire Alarm System In Working Order Explanation _____	Yes	No	N/A
Carbon Monoxide System In Working Order Explanation _____	Yes	No	N/A
Flammable and Combustible Storage Organized Explanation _____	Yes	No	N/A
Trash Waste and Dumpsters Organized Explanation _____	Yes	No	N/A
Cutting and Welding Processes Being Used Safely Explanation _____	Yes	No	N/A
Roofing Processes Being Used Safely Explanation _____	Yes	No	N/A
Temporary and Portable Heaters Being Used Safely Explanation _____	Yes	No	N/A
Building Utilities Being Used Safely Explanation _____	Yes	No	N/A
Smoking Areas and Receptacles Being Used Safely Explanation _____	Yes	No	N/A
Unusual Hazards Explanation _____		Yes	No